

	Results	WHO Drinking Water limits	Limits Exceeded (Y/N)
Sample_ID	DB1_apr19		
Sampling date	10.04.2019		
Location ID	Devonshire Building		
Sample description	Rainwater Harvesting System		
Sample Source	Rainwater		
Label	RW		
Latitude	54.981095		
Longitude	-1.6135311		
Sea Level (mAOD)			
Depth below ground (m)			
pH			
Temp (degC)			
Salinity (ppm)			
TDS (mg/l)			
Conductivity (uS)			
Alkalinity (mg/L CaCO3)	66		
Faecal Coliforms (count/100ml)	0	0	N
Aluminium (mg/l)	0.010	0.2	N
Ammonium (mg/l)	0.015	<i>Not of health concerns at levels found in drinking water</i>	N
Antimony (mg/l)	0.005	0.02	N
Arsenic (mg/l)	0.005	0.01	N
Barium (mg/l)	0.060	1.3	N
Bromide (mg/l)		6	N
Cadmium (mg/l)	0.000	0.003	N
Calcium (mg/l)	41.614	100-300	N
Chloride (mg/l)	4.032	250	N
Chromium (mg/l)	0.001	0.05	N
Copper (mg/l)	0.002	2	N
Fluoride (mg/l)	0.833	1.5	N

Iron (mg/l)	0.001	2	N
Lead (mg/l)	0.001	0.01	N
Magnesium (mg/l)	5.420	<i>Not of health concerns at levels found in drinking water</i>	N
Manganese (mg/l)	0.001	0.4	N
Nickel (mg/l)	0.001	0.07	N
Nitrate (mg/l) (HACH)	1.170	50	N
Nitrate.1 (mg/l) (Ion Chrom)	0.902	50	N
Nitrite (mg/l) (HACH)	0.015	3	N
Nitrite.1 (mg/l) (Ion Chrom)	0.019	3	N
Phosphate (mg/l)	0.548	<i>Not of health concerns at levels found in drinking water</i>	N
Potassium (mg/l)	1.342	<i>Not of health concerns at levels found in drinking water</i>	N
Silicon (mg/l)	1.817	<i>Not of health concerns at levels found in drinking water</i>	N
Sodium (mg/l)	17.129	200	N
Strontium (mg/l)	0.175	4	N
Sulphate (mg/l)	11.675	500	N
Zinc (mg/l)	0.009	<i>Not of health concerns at levels found in drinking water</i>	N
TOC (mg/l)			
TIC (mg/l)			
UV abs 200 (cm-1)	0.879		
UV abs 210 (cm-1)	0.699		
UV abs 220 (cm-1)	0.331		
UV abs 230 (cm-1)	0.118		
UV abs 254 (cm-1)	0.639		
UV abs 260 (cm-1)	0.035		
UV abs 280 (cm-1)	0.025		
UV abs 300 (cm-1)	0.017		
Total Coliforms (total count)	0		

Putative Pathogens - Human E.coli (total count)			
Putative Pathogens - Total E.coli (total count)			
Putative Pathogens - Total Coliform (total count)			
Total Bacteria (total count)			
Enterococci (count/100ml)			
Contaminants	Water considered safe on date of sample		
Health Effects			
Treatments			